

# Homespring™ Central Water Purifier





## Technical Specifications

Maximum Peak Flow Rate (LPM/USgal)	Up to 42/11
Maximum Continuous Flow Rate (LPM/USgal)	17/4.5
Minimum Temperature (°C/°F)	> 0/32
Maximum Temperature	> 38/100
Approximate Flush Volume (litres/USgal)*	45/12
Typical System Efficiency*	95%
Controller Voltage (VAC)	120/230
Bacteria Removal**	> 99.99999%
Virus Removal**	> 99.999%
Cyst Removal**	> 99.99%

\* Depends upon model, water quality and flowrate  
 \*\*Please see certification and testing data for more information  
 Applicable to model #UF 207, UFC 207, UF 209, UFC 209, UF 211, UFC 211




Homespring™ model number	<b>UFC 211</b> <b>UF 211</b>
Maximum rated peak flow in gallons (litres) per minute	11 GPM (42 LPM)
Maximum rated continuous flow in gallons (litres) per minute	4.5 GPM (17 LPM)
Approximate water volume treated annually in gallons (litres)	130,000 gallons (0.49 millions litres)
Estimated carbon filter capacity in gallons (litres)	130,000 gallons (0.49 millions litres)
Number of people in home	5 or more
Number of bathrooms	2.5 – 3.5
Maximum ambient temperature	60° (140°F)
Homespring™ controllers	 <b>Advanced plus</b>
<p>All systems have the capacity to effectively filter water from either surface/lake, well, or municipal water supplies.</p> <p>Additional pre-filtration may be required depending on water source.</p>	



NELAP\* and California Department of Health accredited laboratory\*  
 National Environmental Laboratory Accreditation Program (NELAP) Accredited #6224CA  
 The ZENON UF200 Series™ Water Purifiers have been tested by BioVir® Laboratories Inc. and found to meet all the requirements of the USEPA's Guide Standard Protocol for Testing Microbiological Water Purifiers (IOPP Task Force Report, 1987) as interpreted by the BioVir® Laboratories specifically for the ZENON UF 200 Series Products.

The test results were:  
 Bacteria Reduction™ > 99.99999%  
 Virus Reduction™ > 99.999%  
 Applies to the following models: UF 207, UFC 207, UF 209, UFC 209, UF 211, UFC 211



System Tested and Certified by NSF International against NSF/ANSI 42 and 53 for:

- Cyst Reduction
- Particulate Reduction - Class 1
- Turbidity Reduction
- Chlorine, Taste and Odor

The Homespring™ UF 200 Water Filtration System should only be installed where the System and the installation complies with state and local laws and regulations.

The Homespring™ UF 200 Water Filtration System should only be used to filter water that is cold. The Homespring™ UF 200 Water Filtration System conforms with ANSI/NSF 42/53 for the specific performance claims as verified and substantiated by test data.

**Distribué par :**  
**ozone.ch SARL**  
 Chemin des Aulnes 1, 2400 Le Locle, Suisse  
 Tél: ++41(0)32-841 77 55 Fax: ++41(0)32-841 77 57  
 Email : info@ozone.ch Web : http://www.ozone.ch

The ZENON UF 200 Series™ Water Purifiers are NSF International Certified and Certified by the USEPA's Guide Standard Protocol for Testing Microbiological Water Purifiers (IOPP Task Force Report, 1987) as interpreted by the BioVir® Laboratories specifically for the ZENON UF 200 Series Products.